ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0224 Rev. 00

Holder of Attestation: **Suzhou Inovance Technology Co., Ltd.**
No. 52, Tian E Dang Road, Wuzhong District
215104 Suzhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic frequency converter (AC Drive)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105213060502

Date, 2025-09-24

(Kevin Liu)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0224 Rev. 00

Model(s): **MD310T0.4B(a), MD310T0.7B(a), MD310T1.5B(a), MD310T2.2B(a), MD310T3.7B(a), MD310T5.5B(a), MD310T7.5B(a), MD310T11B(a), MD310T15B(a), MD310T18.5B(a)**

Remark:
Note (a): The model number may include a suffix "XXXXXXXXXX", Where "XXXXXXXXXX" can be blank or combination of any alphanumeric and/or symbols that represents customer identity

Brand: **INOVANCE**

Parameters:

Model No.	Rated Input	Rated Output	Size (mm)
MD310T0.4B(a)	3 PH, 380-440V, 50/60Hz, 1.9A	3 PH, 0-440V, 0-500Hz, 1.5A, 0.4kW	128*108*158
MD310T0.7B(a)	3 PH, 380-440V, 50/60Hz, 3.4A	3 PH, 0-440V, 0-500Hz, 2.1A, 0.75kW	
MD310T1.5B(a)	3 PH, 380-440V, 50/60Hz, 5.0A	3 PH, 0-440V, 0-500Hz, 3.8A, 1.5kW	
MD310T2.2B(a)	3 PH, 380-440V, 50/60Hz, 5.8A	3 PH, 0-440V, 0-500Hz, 5.1A, 2.2kW	
MD310T3.7B(a)	3 PH, 380-440V, 50/60Hz, 10.5A	3 PH, 0-440V, 0-500Hz, 9A, 3.7kW	185 *130*164

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0224 Rev. 00

MD310T5.5B(a)	3 PH, 380-440V, 50/60Hz, 14.6A	3 PH, 0-440V, 0-500Hz, 13A,5.5kW	
MD310T7.5B(a)	3 PH, 380-440V, 50/60Hz, 20.5A	3 PH, 0-440V, 0-500Hz, 17A, 7.5kW	234*140*171
MD310T11B(a)	3 PH, 380-440V, 50/60Hz, 26A	3 PH, 0-440V, 0-500Hz, 25A, 11kW	
MD310T15B(a)	3 PH, 380-440V, 50/60Hz, 35A	3 PH, 0-440V, 0-500Hz, 32A, 15kW	270*180*175.5
MD310T18.5B(a)	3 PH, 380-440V, 50/60Hz, 38.5A	3 PH, 0-440V, 0-500Hz, 37A, 18.5kW	

Remark:

- When installing the equipment, all requirements of the mentioned standard must be fulfilled and it should be suitably installed in closed electrical operation area, and fire/mechanical protection enclosure shall be provided.
- The equipment has no overcurrent protective device. For safety operation, a suitable external circuit breaker must be employed before installation.

Tested according to: EN 61800-5-1:2007/A11:2021

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®