ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0028 Rev. 01

Holder of Attestation: **Suzhou Inovance Technology Co., Ltd.**
No. 52, Tian E Dang Road, Wuzhong District
215104 Suzhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic frequency converter (AC Drive)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105233150703

Date, 2025-01-17

(Kevin Liu)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0028 Rev. 01

Model(s): **ES680N-4T312S-C1-V(a), ES680N-4T395S-C1-V(a), ES680N-4T426S-C1-V(a), ES680N-4T480S-C1-V(a), ES680N-4T525S-C1-V(a), ES680N-4T600S-C1-V(a), ES680N-4T650S-C1-V(a), ES680N-4T312S(a), ES680N-4T395S(a), ES680N-4T426S(a), ES680N-4T480S(a), ES680N-4T525S(a), ES680N-4T600S(a), ES680N-4T650S(a), ES680N-4T312S-C1(a), ES680N-4T312S-C1-CEN(a), ES680N-4T312S-C1-M(a), ES680N-4T395S-C1(a), ES680N-4T395S-C1-CEN(a), ES680N-4T395S-C1-M(a), ES680N-4T426S-C1(a), ES680N-4T426S-C1-CEN(a), ES680N-4T426S-C1-M(a), ES680N-4T480S-C1(a), ES680N-4T480S-C1-CEN(a), ES680N-4T480S-C1-M(a), ES680N-4T525S-C1(a), ES680N-4T525S-C1-CEN(a), ES680N-4T525S-C1-M(a), ES680N-4T600S-C1(a), ES680N-4T600S-C1-CEN(a), ES680N-4T600S-C1-M(a), ES680N-4T650S-C1(a), ES680N-4T650S-C1-CEN(a), ES680N-4T650S-C1-M(a)**

Remark:

(a): The model number may include a suffix "XXXXXXXXXX", Where "XXXXXXXXXX" can be blank or combination of any alphanumeric and/or symbols that represents customer identity.

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0028 Rev. 01

Parameters:

Construction: Built-in

Remark:

- When installing the equipment, all requirements of the mentioned standard must be fulfilled and it should be suitably installed in closed electrical operation area, and fire/mechanical protection enclosure shall be provided.
- For safe operation, a suitable external circuit breaker or fuse must be employed before installation.

Model No.	Rated Input	Rated Output	Size (mm)
ES680N-4T312S-C1-V(a)	3PH AC 380-480V 287 .0A 50/60Hz	3PH AC 0-480V 312.0A 0-400Hz 160kW	757*630*324
ES680N-4T312S-C1(a)			
ES680N-4T312S-C1-CEN(a)			
ES680N-4T312S-C1-M(a)			
ES680N-4T312S(a)			
ES680N-4T395S-C1-V(a)	3PH AC 380-480V 365 .0A 50/60Hz	3PH AC 0-480V 395.0A 0-400Hz 200kW	
ES680N-4T395S-C1(a)			
ES680N-4T395S-C1-CEN(a)			
ES680N-4T395S-C1-M(a)			
ES680N-4T395S(a)			
ES680N-4T426S-C1-V(a)	3PH AC 380-480V 410 .0A 50/60Hz	3PH AC 0-480V 426.0A 0-400Hz 220kW	
ES680N-4T426S-C1(a)			
ES680N-4T426S-C1-CEN(a)			
ES680N-4T426S-C1-M(a)			
ES680N-4T426S(a)			
ES680N-4T480S-C1-V(a)	3PH AC 380-480V 441 .0A 50Hz/60Hz	3PH AC 0-480V 480.0A 0-400Hz 250kW	
ES680N-4T480S-C1(a)			
ES680N-4T480S-C1-CEN(a)			
ES680N-4T480S-C1-M(a)			
ES680N-4T480S(a)			
ES680N-4T525S-C1-V(a)	3PH AC 380-480V 495 .0A 50Hz/60Hz	3PH AC 0-480V 525.0A 0-400Hz 280kW	
ES680N-4T525S-C1(a)			
ES680N-4T525S-C1-CEN(a)			
ES680N-4T525S-C1-M(a)			

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0028 Rev. 01

ES680N-4T525S(a)			
ES680N-4T600S-C1-V(a)	3PH AC 380-480V 565 .0A 50Hz/60Hz	3PH AC 0-480V 600.0A 0-400Hz 315kW	
ES680N-4T600S-C1(a)			
ES680N-4T600S-C1-CEN(a)			
ES680N-4T600S-C1-M(a)			
ES680N-4T600S(a)			
ES680N-4T650S-C1-V(a)	3PH AC 380-480V 617 .0A 50Hz/60Hz	3PH AC 0-480V 650.0A 0-400Hz 355kW	
ES680N-4T650S-C1(a)			
ES680N-4T650S-C1-CEN(a)			
ES680N-4T650S-C1-M(a)			
ES680N-4T650S(a)			

Tested according to: EN 61800-5-1:2007/A11:2021

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®