ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. E8A 092835 0070 Rev. 00

Holder of Attestation: **Suzhou Inovance Technology Co., Ltd.**
No. 52, Tian E Dang Road, Wuzhong District
215104 Suzhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Electronic frequency converter (AC Drive)**

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 6877224008001

Date, 2025-03-14

(Laurent Yuan)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. E8A 092835 0070 Rev. 00

Model(s):

MD630S-4T3R8BS(a), MD630S-4T037BS(a), MD630S-4T045BS(a), MD630N-4T037BS(a), MD630N-4T045BS(a)
[(a): The model number may include a suffix "XXXXXXXXXX", Where "XXXXXXXXXX" can be blank or combination of any alphanumeric and/or symbols that represents customer identity.]

Description of Object:

Ratings: See below table for details

Model No.	G Rated	P Rated
MD630S-4T3R8BS(a)	Input:380-480V AC 50/60Hz 4.6A Output:0-480V 0-599Hz 3.8A 1.5kW	Input:380-480V AC 50/60Hz 6.4A Output:0-480V 0-599Hz 5.1A 2.2kW
MD630S-4T037BS(a)	Input:380-480V AC 50/60Hz 48.7A Output:0-480V 0-599Hz 37A 18.5kW	Input:380-480V AC 50/60Hz 60.1A Output:0-480V 0-599Hz 45A 22kW
MD630S-4T045BS(a)	Input:380-480V AC 50/60Hz 58.5A Output:0-480V 0-599Hz 45A 22kW	Input:380-480V AC 50/60Hz 71.6A Output:0-480V 0-599Hz 60A 30kW
MD630N-4T037BS(a)	Input:380-480V AC 50/60Hz 48.7A Output:0-480V 0-599Hz 37A 18.5kW	Input:380-480V AC 50/60Hz 60.1A Output:0-480V 0-599Hz 45A 22kW
MD630N-4T045BS(a)	Input:380-480V AC 50/60Hz 58.5A Output:0-480V 0-599Hz 45A 22kW	Input:380-480V AC 50/60Hz 71.6A Output:0-480V 0-599Hz 60A 30kW

Tested according to:

EN 61800-3:2004/A1:2012
EN IEC 61800-3:2018
EN IEC 61800-3:2023
EN 55011:2016/A2:2021
EN 61000-6-4:2007/A1:2011
EN IEC 61000-6-4:2019
EN 61000-6-2:2005
EN IEC 61000-6-2:2019

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®