ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0113 Rev. 00

Holder of Attestation: **Suzhou Inovance Technology Co., Ltd.**
No. 52, Tian E Dang Road, Wuzhong District
215104 Suzhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic frequency converter (AC Drive)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105223189402

Date, 2025-06-04

(Kevin Liu)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0113 Rev. 00

Model(s):

MD580-01S-07A4-7-B(a),
MD580-01S-09A9-7-B(a),
MD580-01S-14A3-7-B(a),
MD580-01S-0019-7-B(a),
MD580-01S-0023-7-B(a),
MD580-01S-0027-7-B(a),
MD580-01S-07A4-7-B-LCD(a),
MD580-01S-09A9-7-B-LCD(a),
MD580-01S-14A3-7-B-LCD(a),
MD580-01S-0019-7-B-LCD(a),
MD580-01S-0023-7-B-LCD(a),
MD580-01S-0027-7-B-LCD(a),
MD580-7T7R4B-S(a),
MD580-7T9R9B-S(a),
MD580-7T14R3B-S(a),
MD580-7T19B-S(a),
MD580-7T23B-S(a),
MD580-7T27B-S(a),
MD580-7T7R4B-LCD-S(a),
MD580-7T9R9B-LCD-S(a),
MD580-7T14R3B-LCD-S(a),
MD580-7T19B-LCD-S(a),
MD580-7T23B-LCD-S(a),
MD580-7T27B-LCD-S(a)

Remark: "(a)" The model number may include a suffix "XXXXXXXXXX", where "XXXXXXXXXX" can be blank or combination of any alphanumeric and/or symbols that represents customer identity.

Parameters:

Construction: Built-in

Model No.	Rated Input	Rated Output	Size (mm)
MD580-01S-07A4-7-B(a)	3P 525-690Vac 50/60Hz, 7A	3P 0-690Vac,7.4A, 0-599Hz,5.5kW	420*170*225
MD580-7T7R4B-S(a)			

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0113 Rev. 00

MD580-01S-09A9-7-B(a) MD580-7T9R9B-S(a)	3P 525-690Vac 50/60Hz, 9A	3P 0-690Vac,9.9A, 0-599Hz,7.5kW	420*170*225
MD580-01S-14A3-7-B(a) MD580-7T14R3B-S(a)	3P 525-690Vac 50/60Hz, 13A	3P 0-690Vac,14.3A, 0-599Hz,11kW	420*170*225
MD580-01S-0019-7-B(a) MD580-7T19B-S(a)	3P 525-690Vac 50/60Hz, 17A	3P 0-690Vac,19A, 0-599Hz, 15kW	420*170*225
MD580-01S-0023-7-B(a) MD580-7T23B-S(a)	3P 525-690Vac 50/60Hz, 21A	3P 0-690Vac,23A, 0-599Hz,18.5kW	420*170*225
MD580-01S-0027-7-B(a) MD580-7T27B-S(a)	3P 525-690Vac 50/60Hz, 25A	3P 0-690Vac,27A, 0-599Hz,22kW	420*170*225
MD580-01S-07A4-7-B-LCD(a) MD580-7T7R4B-LCD-S(a)	3P 525-690Vac 50/60Hz, 7A	3P 0-690Vac,7.4A, 0-599Hz,5.5kW	420*170*225
MD580-01S-09A9-7-B-LCD(a) MD580-7T9R9B-LCD-S(a)	3P 525-690Vac 50/60Hz, 9A	3P 0-690Vac,9.9A, 0-599Hz,7.5kW	420*170*225
MD580-01S-14A3-7-B-LCD(a) MD580-7T14R3B-LCD-S(a)	3P 525-690Vac 50/60Hz, 13A	3P 0-690Vac,14.3A, 0-599Hz,11kW	420*170*225
MD580-01S-0019-7-B-LCD(a) MD580-7T19B-LCD-S(a)	3P 525-690Vac 50/60Hz, 17A	3P 0-690Vac,19A, 0-599Hz, 15kW	420*170*225
MD580-01S-0023-7-B-LCD(a) MD580-7T23B-LCD-S(a)	3P 525-690Vac 50/60Hz, 21A	3P 0-690Vac,23A, 0-599Hz,18.5kW	420*170*225
MD580-01S-0027-7-B-LCD(a) MD580-7T27B-LCD-S(a)	3P 525-690Vac 50/60Hz, 25A	3P 0-690Vac,27A, 0-599Hz,22kW	420*170*225

Remark:

- When installing the equipment, all requirements of the mentioned standard must be fulfilled and it should be suitably installed in closed electrical operation area, and fire/mechanical protection enclosure shall be provided.
- For safe operation, a suitable external circuit breaker or fuse must be employed before installation.

Tested according to: EN 61800-5-1:2007/A11:2021

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®