ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0213 Rev. 00

Holder of Attestation: **Suzhou Inovance Technology Co., Ltd.**
No. 52, Tian E Dang Road, Wuzhong District
215104 Suzhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic frequency converter (Integrated Escalator Controller AC Drive / Elevator AC Drive)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105193085602

Date, 2025-09-23

(Kevin Liu)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0213 Rev. 00

Model(s):

NICE-E1-B-4017(a),
NICE-E1-B-4025(a),
NICE-E1-B-4032(a),
ME320LN-4007-SA-INT(a),
ME320LN-4011-SA-INT(a),
ME320LN-4015-SA-INT(a)

Remark:
"(a)" The model number may include a suffix "XXXXXXXXXX", where "XXXXXXXXXX" can be blank or combination of any alphanumeric and/or symbols that represents customer identity.

Parameters:

Ambient temperature:	50°C
Overvoltage category:	III
Pullotion dgree:	2
Construction:	Built-in
IP code:	IP20

Table 1- Model list

	Model No.	Rated Input	Rated Output
Integrated Escalator Controller AC Drive	NICE-E1-B-4017(a)	3PH, AC 380-440V, 50/60Hz, 20.5A	3PH, AC 0-440V, 0-90Hz, 17.0A, 7.5kW
	NICE-E1-B-4025(a)	3PH, AC 380-440V, 50/60Hz, 26.0A	3PH, AC 0-440V, 0-90Hz, 25.0A, 11.0kW
	NICE-E1-B-4032(a)	3PH, AC 380-440V, 50/60Hz, 35.0A	3PH, AC 0-440V, 0-90Hz, 32.0A, 15.0kW
Elevator AC Drive	ME320LN-4007-SA-INT(a)	3PH, AC 380-440V, 50/60Hz, 20.5A	3PH, AC 0-440V, 0-90Hz, 18.0A, 7.5kW
	ME320LN-4011-SA-INT(a)	3PH, AC 380-440V, 50/60Hz, 29.0A	3PH, AC 0-440V, 0-90Hz, 27.0A, 11.0kW
	ME320LN-4015-SA-INT(a)	3PH, AC 380-440V, 50/60Hz, 36.0A	3PH, AC 0-440V, 0-90Hz, 33.0A, 15.0kW

Tested according to: EN 61800-5-1:2007/A11:2021

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®