ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0233 Rev. 00

Holder of Attestation: **Suzhou Inovance Technology Co., Ltd.**
No. 52, Tian E Dang Road, Wuzhong District
215104 Suzhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic frequency converter [AC Drive/AC Servo Drive (Drive Unit)]**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105203066802

Date, 2025-09-22

Kevin Liu

(Kevin Liu)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0233 Rev. 00

Model(s):

MD810-50M4T45Gxyz(a), MD810-50M4T55Gxyz(a), MD810-50M4T75Gxyz(a), MD880-50M-0116-4(a), MD880-50M-0149-4(a), MD880-50M-0183-4(a), ES810-50M4T091-xy(a), ES810-50M4T112-xy(a), ES810-50M4T150-xy(a), IS810N50M4TS090INT(a), IS810N50M4TS112INT(a), IS810N50M4TS152INT(a), IS810P-50M4T091-C(a), IS810P-50M4T112-C(a), IS810P-50M4T150-C(a), IS810P-50M4T091-CO(a), IS810P-50M4T112-CO(a), IS810P-50M4T150-CO(a), IS810F50M4T091(a), IS810F50M4T112(a), IS810F50M4T150(a)

Remark:
x represents optional function part, which can be 0-9;
y represents optional communication part, which can be 0-9;
z represents optional extension part which can be 0-9;
(a): The model number may include a suffix "XXXXXXXXXX", where "XXXXXXXXXX" can be blank or combination of any alphanumeric and/or symbols that represents customer identity.

Brand:

INOVANCE

Parameters:

Construction:	Built-in
Overvoltage category:	III
Remark: - When installing the equipment, all requirements of the mentioned standard must be fulfilled and it should be suitably installed in closed electrical operation area, and fire/mechanical protection enclosure shall be provided. - For safe operation, a suitable external circuit breaker or fuse must be employed before installation.	

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0233 Rev. 00

Model No.	Rated Input	Rated Output
MD810-50M4T45Gxyz(a)	DC 537-679V, 105A	3PH AC 0-480V, 91A, 0-500Hz, 45kW
MD810-50M4T55Gxyz(a)	DC 537-679V, 129A	3PH AC 0-480V, 112A, 0-500Hz, 55kW
MD810-50M4T75Gxyz(a)	DC 537-679V, 172A	3PH AC 0-480V, 150A, 0-500Hz, 75kW
MD880-50M-0116-4(a)	DC 537-679V, 146A	3PH AC 0-415V, 116A, 0-300Hz, 55kW
MD880-50M-0149-4(a)	DC 537-679V, 179A	3PH AC 0-415V, 150A, 0-300Hz, 75kW
MD880-50M-0183-4(a)	DC 537-679V, 240A	3PH AC 0-415V, 183A, 0-300Hz, 90kW
ES810-50M4T091-xy(a)	DC 537-679V, 105A	3PH AC 0-480V, 91A, 0-300Hz, 45kW
ES810-50M4T112-xy(a)	DC 537-679V, 129A	3PH AC 0-480V, 112A, 0-300Hz, 55kW
ES810-50M4T150-xy(a)	DC 537-679V, 172A	3PH AC 0-480V, 150A, 0-300Hz, 75kW
IS810N50M4TS090INT(a)	DC 537-679V, 105A	3PH AC 0-380V, 91A, 0-400Hz, 45kW
IS810N50M4TS112INT(a)	DC 537-679V, 129A	3PH AC 0-380V, 112A, 0-400Hz, 55kW
IS810N50M4TS152INT(a)	DC 537-679V, 172A	3PH AC 0-380V, 152A, 0-400Hz, 75kW
IS810P-50M4T091-C(a)	DC 537-679V, 105A	3PH AC 0-380V, 91A, 0-400Hz
IS810P-50M4T112-C(a)	DC 537-679V, 129A	3PH AC 0-380V, 112A, 0-400Hz
IS810P-50M4T150-C(a)	DC 537-679V, 172A	3PH AC 0-380V, 150A, 0-400Hz
IS810P-50M4T091-CO(a)	DC 537-679V, 105A	3PH AC 0-380V, 91A, 0-400Hz
IS810P-50M4T112-CO(a)	DC 537-679V, 129A	3PH AC 0-380V, 112A, 0-400Hz
IS810P-50M4T150-CO(a)	DC 537-679V, 172A	3PH AC 0-380V, 150A, 0-400Hz
IS810F50M4T091(a)	DC 537-679V, 105A	3PH AC 0-380V, 91A, 0-400Hz
IS810F50M4T112(a)	DC 537-679V, 129A	3PH AC 0-380V, 112A, 0-400Hz
IS810F50M4T150(a)	DC 537-679V, 172A	3PH AC 0-380V, 150A, 0-400Hz

Tested according to: EN 61800-5-1:2007/A11:2021

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®