ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0231 Rev. 00

Holder of Attestation: **Suzhou Inovance Technology Co., Ltd.**
No. 52, Tian E Dang Road, Wuzhong District
215104 Suzhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic frequency converter [AC Drive/AC Servo Drive (Drive Unit)]**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105203066602

Date, 2025-09-22

(Kevin Liu)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0231 Rev. 00

Model(s):

MD810-50M4T11GABY(a), MD810-50M4T15GABY(a), MD810-50M4T18.5GABY(a), MD880-50M-0033-4(a), MD880-50M-0038-4(a), MD880-50M-0048-4(a), ES810-50M4T017-AB(a), ES810-50M4T025-AB(a), ES810-50M4T032-AB(a), ES810-50M4T037-AB(a), IS810P-50M4T017-CO(a), IS810P-50M4T021-CO(a), IS810P-50M4T025-CO(a), IS810P-50M4T032-CO(a), IS810P-50M4T037-CO(a), IS810P-50M4T017-C(a), IS810P-50M4T021-C(a), IS810P-50M4T025-C(a), IS810P-50M4T032-C(a), IS810P-50M4T037-C(a), IS810F50M4T017(a), IS810F50M4T021(a), IS810F50M4T025(a), IS810F50M4T032(a), IS810F50M4T037(a)

Remark:
A represents optional function part, which can be 0-4;
B represents optional communication part, which can be 0-6;
Y represents optional extension part which can be 0 or 1;
(a) The model number may include a suffix "XXXXXXXXXX", where "XXXXXXXXXX" can be blank or combination of any alphanumeric and/or symbols that represents customer identity.

Brand:

INOVANCE

Parameters:

Construction:	Built-in
Overvoltage category:	III
Remark: - When installing the equipment, all requirements of the mentioned standard must be fulfilled and it should be suitably installed in closed electrical operation area, and fire/mechanical protection enclosure shall be provided. - For safe operation, a suitable external circuit breaker or fuse must be employed before installation.	

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0231 Rev. 00

Model No.	Rated Input	Rated Output
MD810-50M4T11GABY(a)	DC 537-679V, 31A	3PH AC 0-480V, 25A, 0-500Hz, 11kW
MD810-50M4T15GABY(a)	DC 537-679V, 40A	3PH AC 0-480V, 32A, 0-500Hz, 15kW
MD810-50M4T18.5GABY(a)	DC 537-679V, 46A	3PH AC 0-480V, 37A, 0-500Hz, 18.5kW
MD880-50M-0033-4(a)	DC 537-679V, 40A	3PH AC 0-415V, 33A, 0-300Hz, 15kW
MD880-50M-0038-4(a)	DC 537-679V, 51A	3PH AC 0-415V, 38A, 0-300Hz, 18.5kW
MD880-50M-0048-4(a)	DC 537-679V, 59A	3PH AC 0-415V, 48A, 0-300Hz, 22kW
ES810-50M4T017-AB(a)	DC 537-679V, 22A	3PH AC 0-480V, 17A, 0-300Hz, 7.5kW
ES810-50M4T025-AB(a)	DC 537-679V, 31A	3PH AC 0-480V, 25A, 0-300Hz, 11kW
ES810-50M4T032-AB(a)	DC 537-679V, 40A	3PH AC 0-480V, 32A, 0-300Hz, 15kW
ES810-50M4T037-AB(a)	DC 537-679V, 46A	3PH AC 0-480V, 37A, 0-300Hz, 18.5kW
IS810P-50M4T017-CO(a)	DC 537-679V, 21A	3PH AC 0-380V, 17A, 0-400Hz
IS810P-50M4T021-CO(a)	DC 537-679V, 26A	3PH AC 0-380V, 20.8A, 0-400Hz
IS810P-50M4T025-CO(a)	DC 537-679V, 31A	3PH AC 0-380V, 25A, 0-400Hz
IS810P-50M4T032-CO(a)	DC 537-679V, 40A	3PH AC 0-380V, 32A, 0-400Hz
IS810P-50M4T037-CO(a)	DC 537-679V, 46A	3PH AC 0-380V, 37A, 0-400Hz
IS810P-50M4T017-C(a)	DC 537-679V, 21A	3PH AC 0-380V, 17A, 0-400Hz
IS810P-50M4T021-C(a)	DC 537-679V, 26A	3PH AC 0-380V, 20.8A, 0-400Hz
IS810P-50M4T025-C(a)	DC 537-679V, 31A	3PH AC 0-380V, 25A, 0-400Hz
IS810P-50M4T032-C(a)	DC 537-679V, 40A	3PH AC 0-380V, 32A, 0-400Hz
IS810P-50M4T037-C(a)	DC 537-679V, 46A	3PH AC 0-380V, 37A, 0-400Hz
IS810F50M4T017(a)	DC 537-679V, 21A	3PH AC 0-380V, 17A, 0-400Hz
IS810F50M4T021(a)	DC 537-679V, 26A	3PH AC 0-380V, 20.8A, 0-400Hz
IS810F50M4T025(a)	DC 537-679V, 31A	3PH AC 0-380V, 25A, 0-400Hz
IS810F50M4T032(a)	DC 537-679V, 40A	3PH AC 0-380V, 32A, 0-400Hz
IS810F50M4T037(a)	DC 537-679V, 46A	3PH AC 0-380V, 37A, 0-400Hz

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0231 Rev. 00

Tested according to: EN 61800-5-1:2007/A11:2021

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®