ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0267 Rev. 00

Holder of Attestation: **Suzhou Inovance Technology Co., Ltd.**
No. 52, Tian E Dang Road, Wuzhong District
215104 Suzhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic frequency converter (AC Drive)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105193084408

Date, 2025-12-05

Kevin Li

(Kevin Liu)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0267 Rev. 00

Model(s):

**MD500T3.7GB(a), MD500T5.5GB(a),
MD500ET3.7GB(a), MD500ET5.5GB(a),
CS710-4T3.7GB(a), CS710-4T5.5GB(a),
MD290T3.7G/5.5PB(a), MD290T5.5G/7.5PB(a),
MD500T3.7G/5.5PB-PLUS(a),
MD500T5.5G/7.5PB-PLUS(a) ,
MD500T3.7GB-PLUS(a),
MD500T5.5GB-PLUS(a),
MD500-2S0.4GB(a), MD500-2S0.7GB(a),
MD500-2S1.5GB(a), MD500-2S2.2GB(a),
MD500-2S3.0GB(a),
MD500-2S0.4GB-PLUS(a),
MD500-2S0.7GB-PLUS (a),
MD500-2S1.5GB-PLUS (a),
MD500-2S2.2GB-PLUS (a),
MD500-2S3.0GB-PLUS (a),
MD290-2S0.4GB(a), MD290-2S0.7GB(a),
MD290-2S1.5GB(a), MD290-2S2.2GB(a),
MD290-2S3.0GB(a), MD290T5.5G/7.5PB(a),
MD500L-T3.7GB(a), MD500L-T5.5GB(a),
ES510T009-R1(a), ES510T013-R1(a),
ES510T009-C1(a), ES510T013-C1(a),
MD520-4T3.7B(a), MD520-4T5.5B(a),
MD520-4T3.7BS(a), MD520-4T5.5BS(a),
MD520-2S0.4B(a), MD520-2S0.7B(a),
MD520-2S1.5B(a), MD520-2S2.2B(a),
MD520-2S0.4BS(a), MD520-2S0.7BS(a),
MD520-2S1.5BS(a), MD520-2S2.2BS(a)
MD580-4T13B(a), MD580-4T17B(a),
HVD100E-4T5.5PB(a), HVD100E-4T7.5PB(a),
MD480T3.7GB-PLUS(a), MD480T5.5GB-PLUS(a),
MD500-2T2.2GB (a), MD500-2T3.7GB (a),
MD500E-2T2.2GB (a), MD500E-2T3.7GB (a),
MD290-2T2.2G/3.7PB(a), MD290-2T3.7G/5.5PB (a),
MD500-2T2.2GB-PLUS (a),
MD500-2T3.7GB-PLUS (a), MD520-2T2.2B (a),
MD520-2T3.7B (a), MD520-2T2.2BS(a),
MD520-2T3.7BS(a)**

Remark:
***"(a)"* The model number may include a suffix**

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0267 Rev. 00

"XXXXXXXXXX", where "XXXXXXXXXX" can be blank or combination of any alphanumeric and/or symbols that represents customer identity.

Parameters:

Ambient temperature:	50°C Max.
Overvoltage category:	III
Pullotion dgree:	2
Construction:	Built-in
IP code:	IP20
Maximum operation altitude:	3000m
Size:	200mm*130mm*162mm (other than MD580 series) 395mm*151mm*181.5mm (MD580 series)
Remark: - When installing the equipment, all requirements of the mentioned standard must be fulfilled and it should be suitably installed in closed electrical operation area, and fire/mechanical protection enclosure shall be provided. - The frequency inverter has no overcurrent protective device. For safe operation, a suitable external circuit breaker or fuse must be employed before installation.	

Product	Series	Model No.	Rated Input	Rated Output
AC Drive	MD500	MD500T3.7GB(a)	3PH AC 380-480V 11.4A 50/60Hz	3PH AC 0-480V 9.0A 0-500Hz 3.7kW
		MD500T5.5GB(a)	3PH AC 380-480V 16.7A 50/60Hz	3PH AC 0-480V 13.0A 0-500Hz 5.5kW
	MD500E	MD500ET3.7GB(a)	3PH AC 380-480V 11.4A 50/60Hz	3PH AC 0-480V 9.0A 0-500Hz 3.7kW
		MD500ET5.5GB(a)	3PH AC 380-480V 16.7A 50/60Hz	3PH AC 0-480V 13.0A 0-500Hz 5.5kW
	CS710	CS710-4T3.7GB(a)	3PH AC 380-480V 11.4A 50/60Hz	3PH AC 0-480V 9.0A 0-500Hz 3.7kW
		CS710-4T5.5GB(a)	3PH AC 380-480V 16.7A 50/60Hz	3PH AC 0-480V 13.0A 0-500Hz 5.5kW
	MD290	MD290T3.7G/5.5PB(a)	3PH AC 380-480V 15.9A 50/60Hz	3PH AC 0-480V 13.0A 0-500Hz 5.5kW
		MD290T5.5G/7.5PB(a)	3PH AC 380-480V 22.4A 50/60Hz	3PH AC 0-480V 17.0A 0-500Hz 7.5kW
	MD500-PLUS	MD500T3.7G/5.5PB-PLUS(a)	3PH AC 380-480V 11.4A/15.9A 50/60Hz	3PH AC 0-480V 9A/13A 0-599Hz 3.7kW/5.5kW
		MD500T5.5G/7.5PB-	3PH AC 380-480V	3PH AC 0-480V 13A/17A

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

Product Service

Attestation of Conformity

No. N8A 092835 0267 Rev. 00

		PLUS(a)	16.7A/22.4A 50/60Hz	0-599Hz 5.5kW/7.5kW
		MD500T3.7GB-PLUS(a)	3PH AC 380-480V 11.4A 50/60Hz	3PH AC 0-480V 9.0A 0-599Hz 3.7kW
		MD500T5.5GB-PLUS(a)	3PH AC 380-480V 16.7A 50/60Hz	3PH AC 0-480V 13.0A 0-599Hz 5.5kW
	MD500-2S	MD500-2S0.4GB(a)	1PH AC 200-240V 5.4A 50/60Hz	3PH AC 0-240V 2.3A 0-500Hz 0.4kW
		MD500-2S0.7GB(a)	1PH AC 200-240V 8.2A 50/60Hz	3PH AC 0-240V 4.0A 0-500Hz 0.75kW
		MD500-2S1.5GB(a)	1PH AC 200-240V 14A 50/60Hz	3PH AC 0-240V 7.0A 0-500Hz 1.5kW
		MD500-2S2.2GB(a)	1PH AC 200-240V 20A 50/60Hz	3PH AC 0-240V 9.6A 0-500Hz 2.2kW
		MD500-2S3.0GB(a)	1PH AC 200-240V 27A 50/60Hz	3PH AC 0-240V 12A 0-500Hz 3.0kW
	MD500-2S-PLUS	MD500-2S0.4GB-PLUS(a)	1PH AC 200-240V 5.4A 50/60Hz	3PH AC 0-240V 2.3A 0-599Hz 0.4kW
		MD500-2S0.7GB-PLUS (a)	1PH AC 200-240V 8.2A 50/60Hz	3PH AC 0-240V 4.0A 0-599Hz 0.75kW
		MD500-2S1.5GB-PLUS (a)	1PH AC 200-240V 14A 50/60Hz	3PH AC 0-240V 7.0A 0-599Hz 1.5kW
		MD500-2S2.2GB-PLUS (a)	1PH AC 200-240V 20A 50/60Hz	3PH AC 0-240V 9.6A 0-599Hz 2.2kW
		MD500-2S3.0GB-PLUS (a)	1PH AC 200-240V 27A 50/60Hz	3PH AC 0-240V 12A 0-599Hz 3.0kW
	MD290-2S	MD290-2S0.4GB(a)	1PH AC 200-240V 5.4A 50/60Hz	3PH AC 0-240V 2.3A 0-500Hz 0.4kW
		MD290-2S0.7GB(a)	1PH AC 200-240V 8.2A 50/60Hz	3PH AC 0-240V 4.0A 0-500Hz 0.75kW
		MD290-2S1.5GB(a)	1PH AC 200-240V 14A 50/60Hz	3PH AC 0-240V 7.0A 0-500Hz 1.5kW
		MD290-2S2.2GB(a)	1PH AC 200-240V 20A 50/60Hz	3PH AC 0-240V 9.6A 0-500Hz 2.2kW
		MD290-2S3.0GB(a)	1PH AC 200-240V 27A 50/60Hz	3PH AC 0-240V 12A 0-500Hz 3.0kW
	MD520	MD520-4T3.7B(a)	3PH AC 380-480V 11.4A/15.9A 50/60Hz	3PH AC 0-480V 9A/13A 0-599Hz 3.7kW/5.5kW
		MD520-4T5.5B(a)	3PH AC 380-480V 16.7A/22.4A 50/60Hz	3PH AC 0-480V 13A/17A 0-599Hz 5.5kW/7.5kW
		MD520-4T3.7BS(a)	3PH AC 380-480V 11.4A/15.9A 50/60Hz	3PH AC 0-480V 9A/13A 0-599Hz 3.7kW/5.5kW

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

Product Service

Attestation of Conformity

No. N8A 092835 0267 Rev. 00

		MD520-4T5.5BS(a)	3PH AC 380-480V 16.7A/22.4A 50/60Hz	3PH AC 0-480V 13A/17A 0-599Hz 5.5kW/7.5kW
	MD520-2S	MD520-2S0.4B(a)	1PH AC 200-240V 5.4/8.2A 50/60Hz	3PH AC 0-240V 2.3/4.0A 0-599Hz 0.4/0.75kW
		MD520-2S0.7B(a)	1PH AC 200-240V 8.2/14A 50/60Hz	3PH AC 0-240V 4.0/7.0A 0-599Hz 1.5kW
		MD520-2S1.5B(a)	1PH AC 200-240V 14/20A 50/60Hz	3PH AC 0-240V 7/9.6A 0-599Hz 2.2kW
		MD520-2S2.2B(a)	1PH AC 200-240V 20/27A 50/60Hz	3PH AC 0-240V 9.6/12A 0-599Hz 3.0kW
		MD520-2S0.4BS(a)	1PH AC 200-240V 5.4/8.2A 50/60Hz	3PH AC 0-240V 4.0A 0-599Hz 0.4/0.75kW
		MD520-2S0.7BS(a)	1PH AC 200-240V 8.2/14A 50/60Hz	3PH AC 0-240V 4.0/7.0A 0-599Hz 1.5kW
		MD520-2S1.5BS(a)	1PH AC 200-240V 14/20A 50/60Hz	3PH AC 0-240V 7/9.6A 0-599Hz 2.2kW
		MD520-2S2.2BS(a)	1PH AC 200-240V 20/27A 50/60Hz	3PH AC 0-240V 9.6/12A 0-599Hz 3.0kW
	MD580	MD580-4T13B(a)	3PH AC 380-480V 11.4/15.9A 50/60Hz	3PH AC 0-480V 9.0/13.0A 0-599Hz 3.7/5.5kW
		MD580-4T17B(a)	3PH AC 380-480V 16.7/22.4A 50/60Hz	3PH AC 0-480V 13.0/17.0A 0-599Hz 5.5/7.5kW
	HVD100E	HVD100E-4T5.5PB(a)	3PH AC 380-480V 15.9A 50/60Hz	3PH AC 0-480V 13.0A 0-599Hz 5.5kW
		HVD100E-4T7.5PB(a)	3PH AC 380-480V 22.4A 50/60Hz	3PH AC 0-480V 17.0A 0-599Hz 7.5kW
	MD480-PLUS	MD480T3.7GB-PLUS(a)	3PH AC 380-480V 11.4A 50/60Hz	3PH AC 0-480V 9.0A 0-599Hz 3.7kW
		MD480T5.5GB-PLUS(a)	3PH AC 380-480V 16.7A 50/60Hz	3PH AC 0-480V 13.0A 0-599Hz 5.5kW
	MD500-2T	MD500-2T2.2GB (a)	3PH AC 200-240V 11.4A 50/60Hz	3PH AC 0-240V 9.0A 0-500Hz 2.2kW
		MD500-2T3.7GB (a)	3PH AC 200-240V 16.7A 50/60Hz	3PH AC 0-240V 13.0A 0-500Hz 3.7kW
	MD500E-2T	MD500E-2T2.2GB (a)	3PH AC 200-240V 11.4A 50/60Hz	3PH AC 0-240V 9.0A 0-500Hz 2.2kW
		MD500E-2T3.7GB (a)	3PH AC 200-240V 16.7A 50/60Hz	3PH AC 0-240V 13.0A 0-500Hz 3.7kW
	MD290-2T	MD290-2T2.2G/3.7PB(a)	3PH AC 200-240V 15.9A 50/60Hz	3PH AC 0-240V 13.0A 0-500Hz 3.7kW

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

Product Service

Attestation of Conformity

No. N8A 092835 0267 Rev. 00

		MD290-2T3.7G/5.5PB (a)	3PH AC 200-240V 22.4A 50/60Hz	3PH AC 0-240V 17.0A 0-500Hz 5.5kW
	MD500-2T-PLUS	MD500-2T2.2GB-PLUS (a)	3PH AC 200-240V 11.4A 50/60Hz	3PH AC 0-240V 9.0A 0-500Hz 2.2kW
		MD500-2T3.7GB-PLUS (a)	3PH AC 200-240V 16.7A 50/60Hz	3PH AC 0-240V 13.0A 0-500Hz 3.7kW
	MD520-2T	MD520-2T2.2B (a)	3PH AC 200-240V 11.4A/15.9A 50/60Hz	3PH AC 0-240V 9.0A/13A 0-599Hz 2.2kW/3.7kW
		MD520-2T3.7B (a)	3PH AC 200-240V 16.7A/22.4A 50/60Hz	3PH AC 0-240V 13A/17A 0-599Hz 3.7kW/5.5kW
		MD520-2T2.2BS(a)	3PH AC 200-240V 11.4A/15.9A 50/60Hz	3PH AC 0-240V 9.0A/13A 0-599Hz 2.2kW/3.7kW
		MD520-2T3.7BS(a)	3PH AC 200-240V 16.7A/22.4A 50/60Hz	3PH AC 0-240V 13A/17A 0-599Hz 3.7kW/5.5kW
Elevator AC Drive	MD290	MD290T5.5G/7.5PB(a)	3PH AC 380-480V 15.9A 50/60Hz	3PH AC 0-480V 13.0A 0-500Hz 5.5kW
	MD500L	MD500L-T3.7GB(a)	3PH AC 380-480V 11.4A 50/60Hz	3PH AC 0-480V 9.0A 0-500Hz 3.7kW
		MD500L-T5.5GB(a)	3PH AC 380-480V 16.7A 50/60Hz	3PH AC 0-480V 13.0A 0-500Hz 5.5kW
AC servo Drive	ES510	ES510T009-R1(a)	3PH AC 380-480V 10.9A 50/60Hz	3PH AC 0-480V 9.0A 0-300Hz 3.7kW
		ES510T013-R1(a)	3PH AC 380-480V 15.8A 50/60Hz	3PH AC 0-480V 13.0A 0-300Hz 5.5kW
		ES510T009-C1(a)	3PH AC 380-480V 10.9A 50/60Hz	3PH AC 0-480V 9.0A 0-300Hz 3.7kW
		ES510T013-C1(a)	3PH AC 380-480V 15.8A 50/60Hz	3PH AC 0-480V 13.0A 0-300Hz 5.5kW

License condition

All modelswith input voltage 200-240V~, three phase. When they are used in EU countries, an external 400V~ to 200-240V~ step down transformer should be used.

Tested according to: EN 61800-5-1:2007/A11:2021

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

Product Service

Attestation of Conformity

No. N8A 092835 0267 Rev. 00

Parameters:

Product	Series	Model No.	Rated Input	Rated Output
AC Drive	MD500	MD500T3.7GB(a)	3PH AC 380-480V 11.4A 50/60Hz	3PH AC 0-480V 9.0A 0-500Hz 3.7kW
		MD500T5.5GB(a)	3PH AC 380-480V 16.7A 50/60Hz	3PH AC 0-480V 13.0A 0-500Hz 5.5kW
	MD500E	MD500ET3.7GB(a)	3PH AC 380-480V 11.4A 50/60Hz	3PH AC 0-480V 9.0A 0-500Hz 3.7kW
		MD500ET5.5GB(a)	3PH AC 380-480V 16.7A 50/60Hz	3PH AC 0-480V 13.0A 0-500Hz 5.5kW
	CS710	CS710-4T3.7GB(a)	3PH AC 380-480V 11.4A 50/60Hz	3PH AC 0-480V 9.0A 0-500Hz 3.7kW
		CS710-4T5.5GB(a)	3PH AC 380-480V 16.7A 50/60Hz	3PH AC 0-480V 13.0A 0-500Hz 5.5kW
	MD290	MD290T3.7G/5.5PB(a)	3PH AC 380-480V 15.9A 50/60Hz	3PH AC 0-480V 13.0A 0-500Hz 5.5kW
		MD290T5.5G/7.5PB(a)	3PH AC 380-480V 22.4A 50/60Hz	3PH AC 0-480V 17.0A 0-500Hz 7.5kW
	MD500-PLUS	MD500T3.7G/5.5PB-PLUS(a)	3PH AC 380-480V 11.4A/15.9A 50/60Hz	3PH AC 0-480V 9A/13A 0-599Hz 3.7kW/5.5kW
		MD500T5.5G/7.5PB-PLUS(a)	3PH AC 380-480V 16.7A/22.4A 50/60Hz	3PH AC 0-480V 13A/17A 0-599Hz 5.5kW/7.5kW
		MD500T3.7GB-PLUS(a)	3PH AC 380-480V 11.4A 50/60Hz	3PH AC 0-480V 9.0A 0-599Hz 3.7kW
		MD500T5.5GB-PLUS(a)	3PH AC 380-480V 16.7A 50/60Hz	3PH AC 0-480V 13.0A 0-599Hz 5.5kW
	MD500-2S	MD500-2S0.4GB(a)	1PH AC 200-240V 5.4A 50/60Hz	3PH AC 0-240V 2.3A 0-500Hz 0.4kW
		MD500-2S0.7GB(a)	1PH AC 200-240V 8.2A 50/60Hz	3PH AC 0-240V 4.0A 0-500Hz 0.75kW
		MD500-2S1.5GB(a)	1PH AC 200-240V 14A 50/60Hz	3PH AC 0-240V 7.0A 0-500Hz 1.5kW
		MD500-2S2.2GB(a)	1PH AC 200-240V 20A 50/60Hz	3PH AC 0-240V 9.6A 0-500Hz 2.2kW
		MD500-2S3.0GB(a)	1PH AC 200-240V 27A 50/60Hz	3PH AC 0-240V 12A 0-500Hz 3.0kW
	MD500-2S-PLUS	MD500-2S0.4GB-PLUS(a)	1PH AC 200-240V 5.4A 50/60Hz	3PH AC 0-240V 2.3A 0-599Hz 0.4kW
		MD500-2S0.7GB-PLUS (a)	1PH AC 200-240V 8.2A 50/60Hz	3PH AC 0-240V 4.0A 0-599Hz 0.75kW

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

Product Service

Attestation of Conformity

No. N8A 092835 0267 Rev. 00

		MD500-2S1.5GB-PLUS (a)	1PH AC 200-240V 14A 50/60Hz	3PH AC 0-240V 7.0A 0-599Hz 1.5kW
		MD500-2S2.2GB-PLUS (a)	1PH AC 200-240V 20A 50/60Hz	3PH AC 0-240V 9.6A 0-599Hz 2.2kW
		MD500-2S3.0GB-PLUS (a)	1PH AC 200-240V 27A 50/60Hz	3PH AC 0-240V 12A 0-599Hz 3.0kW
	MD290-2S	MD290-2S0.4GB(a)	1PH AC 200-240V 5.4A 50/60Hz	3PH AC 0-240V 2.3A 0-500Hz 0.4kW
		MD290-2S0.7GB(a)	1PH AC 200-240V 8.2A 50/60Hz	3PH AC 0-240V 4.0A 0-500Hz 0.75kW
		MD290-2S1.5GB(a)	1PH AC 200-240V 14A 50/60Hz	3PH AC 0-240V 7.0A 0-500Hz 1.5kW
		MD290-2S2.2GB(a)	1PH AC 200-240V 20A 50/60Hz	3PH AC 0-240V 9.6A 0-500Hz 2.2kW
		MD290-2S3.0GB(a)	1PH AC 200-240V 27A 50/60Hz	3PH AC 0-240V 12A 0-500Hz 3.0kW
	MD520	MD520-4T3.7B(a)	3PH AC 380-480V 11.4A/15.9A 50/60Hz	3PH AC 0-480V 9A/13A 0-599Hz 3.7kW/5.5kW
		MD520-4T5.5B(a)	3PH AC 380-480V 16.7A/22.4A 50/60Hz	3PH AC 0-480V 13A/17A 0-599Hz 5.5kW/7.5kW
		MD520-4T3.7BS(a)	3PH AC 380-480V 11.4A/15.9A 50/60Hz	3PH AC 0-480V 9A/13A 0-599Hz 3.7kW/5.5kW
		MD520-4T5.5BS(a)	3PH AC 380-480V 16.7A/22.4A 50/60Hz	3PH AC 0-480V 13A/17A 0-599Hz 5.5kW/7.5kW
	MD520-2S	MD520-2S0.4B(a)	1PH AC 200-240V 5.4/8.2A 50/60Hz	3PH AC 0-240V 2.3/4.0A 0-599Hz 0.4/0.75kW
		MD520-2S0.7B(a)	1PH AC 200-240V 8.2/14A 50/60Hz	3PH AC 0-240V 4.0/7.0A 0-599Hz 1.5kW
		MD520-2S1.5B(a)	1PH AC 200-240V 14/20A 50/60Hz	3PH AC 0-240V 7/9.6A 0-599Hz 2.2kW
		MD520-2S2.2B(a)	1PH AC 200-240V 20/27A 50/60Hz	3PH AC 0-240V 9.6/12A 0-599Hz 3.0kW
		MD520-2S0.4BS(a)	1PH AC 200-240V 5.4/8.2A 50/60Hz	3PH AC 0-240V 4.0A 0-599Hz 0.4/0.75kW
		MD520-2S0.7BS(a)	1PH AC 200-240V 8.2/14A 50/60Hz	3PH AC 0-240V 4.0/7.0A 0-599Hz 1.5kW
		MD520-2S1.5BS(a)	1PH AC 200-240V 14/20A 50/60Hz	3PH AC 0-240V 7/9.6A 0-599Hz 2.2kW
		MD520-2S2.2BS(a)	1PH AC 200-240V 20/27A 50/60Hz	3PH AC 0-240V 9.6/12A 0-599Hz 3.0kW

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

Product Service

Attestation of Conformity

No. N8A 092835 0267 Rev. 00

	MD580	MD580-4T13B(a)	3PH AC 380-480V 11.4/15.9A 50/60Hz	3PH AC 0-480V 9.0/13.0A 0-599Hz 3.7/5.5kW
		MD580-4T17B(a)	3PH AC 380-480V 16.7/22.4A 50/60Hz	3PH AC 0-480V 13.0/17.0A 0-599Hz 5.5/7.5kW
	HVD100E	HVD100E-4T5.5PB(a)	3PH AC 380-480V 15.9A 50/60Hz	3PH AC 0-480V 13.0A 0-599Hz 5.5kW
		HVD100E-4T7.5PB(a)	3PH AC 380-480V 22.4A 50/60Hz	3PH AC 0-480V 17.0A 0-599Hz 7.5kW
	MD480-PLUS	MD480T3.7GB-PLUS(a)	3PH AC 380-480V 11.4A 50/60Hz	3PH AC 0-480V 9.0A 0-599Hz 3.7kW
		MD480T5.5GB-PLUS(a)	3PH AC 380-480V 16.7A 50/60Hz	3PH AC 0-480V 13.0A 0-599Hz 5.5kW
	MD500-2T	MD500-2T2.2GB (a)	3PH AC 200-240V 11.4A 50/60Hz	3PH AC 0-240V 9.0A 0-500Hz 2.2kW
		MD500-2T3.7GB (a)	3PH AC 200-240V 16.7A 50/60Hz	3PH AC 0-240V 13.0A 0-500Hz 3.7kW
	MD500E-2T	MD500E-2T2.2GB (a)	3PH AC 200-240V 11.4A 50/60Hz	3PH AC 0-240V 9.0A 0-500Hz 2.2kW
		MD500E-2T3.7GB (a)	3PH AC 200-240V 16.7A 50/60Hz	3PH AC 0-240V 13.0A 0-500Hz 3.7kW
	MD290-2T	MD290-2T2.2G/3.7PB(a)	3PH AC 200-240V 15.9A 50/60Hz	3PH AC 0-240V 13.0A 0-500Hz 3.7kW
		MD290-2T3.7G/5.5PB (a)	3PH AC 200-240V 22.4A 50/60Hz	3PH AC 0-240V 17.0A 0-500Hz 5.5kW
	MD500-2T-PLUS	MD500-2T2.2GB-PLUS (a)	3PH AC 200-240V 11.4A 50/60Hz	3PH AC 0-240V 9.0A 0-500Hz 2.2kW
		MD500-2T3.7GB-PLUS (a)	3PH AC 200-240V 16.7A 50/60Hz	3PH AC 0-240V 13.0A 0-500Hz 3.7kW
	MD520-2T	MD520-2T2.2B (a)	3PH AC 200-240V 11.4A/15.9A 50/60Hz	3PH AC 0-240V 9.0A/13A 0-599Hz 2.2kW/3.7kW
		MD520-2T3.7B (a)	3PH AC 200-240V 16.7A/22.4A 50/60Hz	3PH AC 0-240V 13A/17A 0-599Hz 3.7kW/5.5kW
		MD520-2T2.2BS(a)	3PH AC 200-240V 11.4A/15.9A 50/60Hz	3PH AC 0-240V 9.0A/13A 0-599Hz 2.2kW/3.7kW
		MD520-2T3.7BS(a)	3PH AC 200-240V 16.7A/22.4A 50/60Hz	3PH AC 0-240V 13A/17A 0-599Hz 3.7kW/5.5kW
Elevator AC Drive	MD290	MD290T5.5G/7.5PB(a)	3PH AC 380-480V 15.9A 50/60Hz	3PH AC 0-480V 13.0A 0-500Hz 5.5kW

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

Product Service

Attestation of Conformity

No. N8A 092835 0267 Rev. 00

	MD500L	MD500L-T3.7GB(a)	3PH AC 380-480V 11.4A 50/60Hz	3PH AC 0-480V 9.0A 0-500Hz 3.7kW
		MD500L-T5.5GB(a)	3PH AC 380-480V 16.7A 50/60Hz	3PH AC 0-480V 13.0A 0-500Hz 5.5kW
AC servo Drive	ES510	ES510T009-R1(a)	3PH AC 380-480V 10.9A 50/60Hz	3PH AC 0-480V 9.0A 0-300Hz 3.7kW
		ES510T013-R1(a)	3PH AC 380-480V 15.8A 50/60Hz	3PH AC 0-480V 13.0A 0-300Hz 5.5kW
		ES510T009-C1(a)	3PH AC 380-480V 10.9A 50/60Hz	3PH AC 0-480V 9.0A 0-300Hz 3.7kW
		ES510T013-C1(a)	3PH AC 380-480V 15.8A 50/60Hz	3PH AC 0-480V 13.0A 0-300Hz 5.5kW

License condition

All modelswith input voltage 200-240V~, three phase. When they are used in EU countries, an external 400V~ to 200-240V~ step down transformer should be used.

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®