ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0264 Rev. 00

Holder of Attestation: **Suzhou Inovance Technology Co., Ltd.**
No. 52, Tian E Dang Road, Wuzhong District
215104 Suzhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic frequency converter (AC Drive)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105193082208

Date, 2025-12-05

Kevin Liu

(Kevin Liu)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0264 Rev. 00

Model(s):

MD500T15GB(a), MD500T15G/18.5PB-PLUS(a), MD500T15GB-PLUS(a), MD500ET15GB(a), MD500L-T15GB(a), MD290T15G/18.5PB(a), MD290T15G/18.5PB(a), CS710-4T15GB(a), ES510T032-R1-(a), ES510T037-R1-(a), ES510T032-C1-(a), ES510T037-C1-(a), MD520-4T15B(a), MD520-4T15BS(a), MD580-4T37B(a), HVD100E-4T18.5PB(a), MD480T15GB-PLUS(a), MD500-2T7.5GB(a), MD500E-2T7.5GB(a), MD290-2T7.5G/11PB (a), MD500-2T7.5GB-PLUS(a), MD520-2T7.5B(a), MD520-2T7.5BS(a)

Remark:
(a) The model number may include a suffix "XXXXXXXXXX", where "XXXXXXXXXX" can be blank or combination of any alphanumeric and/or symbols that represents customer identity.

Parameters:

Ambient temperature:	50°C Max.
Overvoltage category:	III
Pullotion dgree:	2
Construction:	Built-in
IP code:	IP20

Remark:

- When installing the equipment, all requirements of the mentioned standard must be fulfilled and it should be suitably installed in closed electrical operation area, and fire/mechanical protection enclosure shall be provided.
- The frequency inverter has no overcurrent protective device. For safe operation, a suitable external circuit breaker or fuse must be employed before installation.

Product	Model No.	Rated Input	Rated Output
AC Drive	MD500T15GB(a)	3PH AC 380-480V, 41.3A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-500Hz, 15.0kW

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0264 Rev. 00

	MD500ET15GB(a)	3PH AC 380-480V, 41.3A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-500Hz, 15.0kW
	MD500T15G/18.5PB-PLUS(a)	3PH AC 380-480V 41.3A/44A 50/60Hz	3PH AC 0-480V 32A/37A 0-599Hz 15kW/18.5kW
	MD500T15GB-PLUS(a)	3PH AC 380-480V, 41.3A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-599Hz, 15.0kW
	CS710-4T15GB(a)	3PH AC 380-480V, 41.3A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-150Hz, 15.0kW
	MD290T15G/18.5PB(a)	3PH AC 380-480V, 44.0A, 50/60Hz	3PH AC 0-480V, 37.0A, 0-500Hz, 18.5kW
	MD520-4T15B(a)	3PH AC 380-480V 41.3A/44A 50/60Hz	3PH AC 0-480V 32A/37A 0-599Hz 15kW/18.5kW
	MD520-4T15BS(a)	3PH AC 380-480V 41.3A/44A 50/60Hz	3PH AC 0-480V 32A/37A 0-599Hz 15kW/18.5kW
	MD580-4T37B(a)	3PH AC 380-480V 41.3/48.6A 50/60Hz	3PH AC 0-480V 32.0/37.0A 0-599Hz 15/18.5kW
	HVD100E-4T18.5PB(a)	3PH AC 380-480V 44.0A 50/60Hz	3PH AC 0-480V 37.0A 0-599Hz 18.5kW
	MD480T15GB-PLUS(a)	3PH AC 380-480V 41.3A 50/60Hz	3PH AC 0-480V 32.0A 0-599Hz 15kW
	MD500-2T7.5GB(a)	3PH AC 200-240V 41.3A 50/60Hz	3PH AC 0-240V 32.0A 0-500Hz 7.5kW
	MD500E-2T7.5GB(a)	3PH AC 200-240V 41.3A 50/60Hz	3PH AC 0-240V 32.0A 0-500Hz 7.5kW
	MD290-2T7.5G/11PB (a)	3PH AC 200-240V 44.0A 50/60Hz	3PH AC 0-240V 37.0A 0-500Hz 11kW
	MD500-2T7.5GB-PLUS(a)	3PH AC 200-240V 41.3A 50/60Hz	3PH AC 0-240V 32.0A 0-500Hz 7.5kW
	MD520-2T7.5B(a)	3PH AC 200-240V 41.3A/44A 50/60Hz	3PH AC 0-240V 32A/37A 0-599Hz 7.5kW/11kW
	MD520-2T7.5BS(a)	3PH AC 200-240V 41.3A/44A 50/60Hz	3PH AC 0-240V 32A/37A 0-599Hz 7.5kW/11kW
AC Servo Drive	ES510T032-R1-(a)	3PH AC 380-480V, 38.7A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-300Hz, 15.0kW
	ES510T037-R1-(a)	3PH AC 380-480V, 44.6A, 50/60Hz	3PH AC 0-480V, 37.0A, 0-300Hz, 18.5kW

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

Product Service

Attestation of Conformity

No. N8A 092835 0264 Rev. 00

AC Servo Drive	ES510T032-C1-(a)	3PH AC 380-480V, 38.7A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-300Hz, 15.0kW
	ES510T037-C1-(a)	3PH AC 380-480V, 44.6A, 50/60Hz	3PH AC 0-480V, 37.0A, 0-300Hz, 18.5kW
Elevator AC Drive	MD290T15G/18.5PB(a)	3PH AC 380-480V, 39.7A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-500Hz, 15.0kW
	MD500L-T15GB(a)	3PH AC 380-480V 41.3A 50/60Hz	3PH AC 0-480V 32.0A 0-500Hz 15.0kW

License condition
All models with input voltage 200-240V~, three phase. When they are used in EU countries, an external 400V~ to 200-240V~ step down transformer should be used.

Tested according to: EN 61800-5-1:2007/A11:2021

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0264 Rev. 00

Parameters:

Product	Model No.	Rated Input	Rated Output
AC Drive	MD500T15GB(a)	3PH AC 380-480V, 41.3A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-500Hz, 15.0kW
	MD500ET15GB(a)	3PH AC 380-480V, 41.3A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-500Hz, 15.0kW
	MD500T15G/18.5PB-PLUS(a)	3PH AC 380-480V 41.3A/44A 50/60Hz	3PH AC 0-480V 32A/37A 0-599Hz 15kW/18.5kW
	MD500T15GB-PLUS(a)	3PH AC 380-480V, 41.3A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-599Hz, 15.0kW
	CS710-4T15GB(a)	3PH AC 380-480V, 41.3A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-150Hz, 15.0kW
	MD290T15G/18.5PB(a)	3PH AC 380-480V, 44.0A, 50/60Hz	3PH AC 0-480V, 37.0A, 0-500Hz, 18.5kW
	MD520-4T15B(a)	3PH AC 380-480V 41.3A/44A 50/60Hz	3PH AC 0-480V 32A/37A 0-599Hz 15kW/18.5kW
	MD520-4T15BS(a)	3PH AC 380-480V 41.3A/44A 50/60Hz	3PH AC 0-480V 32A/37A 0-599Hz 15kW/18.5kW
	MD580-4T37B(a)	3PH AC 380-480V 41.3/48.6A 50/60Hz	3PH AC 0-480V 32.0/37.0A 0-599Hz 15/18.5kW
	HVD100E-4T18.5PB(a)	3PH AC 380-480V 44.0A 50/60Hz	3PH AC 0-480V 37.0A 0-599Hz 18.5kW
	MD480T15GB-PLUS(a)	3PH AC 380-480V 41.3A 50/60Hz	3PH AC 0-480V 32.0A 0-599Hz 15kW
	MD500-2T7.5GB(a)	3PH AC 200-240V 41.3A 50/60Hz	3PH AC 0-240V 32.0A 0-500Hz 7.5kW
	MD500E-2T7.5GB(a)	3PH AC 200-240V 41.3A 50/60Hz	3PH AC 0-240V 32.0A 0-500Hz 7.5kW
	MD290-2T7.5G/11PB (a)	3PH AC 200-240V 44.0A 50/60Hz	3PH AC 0-240V 37.0A 0-500Hz 11kW
	MD500-2T7.5GB-PLUS(a)	3PH AC 200-240V 41.3A 50/60Hz	3PH AC 0-240V 32.0A 0-500Hz 7.5kW
	MD520-2T7.5B(a)	3PH AC 200-240V 41.3A/44A 50/60Hz	3PH AC 0-240V 32A/37A 0-599Hz 7.5kW/11kW
	MD520-2T7.5BS(a)	3PH AC 200-240V 41.3A/44A 50/60Hz	3PH AC 0-240V 32A/37A 0-599Hz 7.5kW/11kW
AC Servo Drive	ES510T032-R1-(a)	3PH AC 380-480V, 38.7A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-300Hz, 15.0kW
	ES510T037-R1-(a)	3PH AC 380-480V, 44.6A, 50/60Hz	3PH AC 0-480V, 37.0A, 0-300Hz, 18.5kW
	ES510T032-C1-(a)	3PH AC 380-480V, 38.7A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-300Hz, 15.0kW
	ES510T037-C1-(a)	3PH AC 380-480V, 44.6A, 50/60Hz	3PH AC 0-480V, 37.0A, 0-300Hz, 18.5kW
Elevator AC Drive	MD290T15G/18.5PB(a)	3PH AC 380-480V, 39.7A, 50/60Hz	3PH AC 0-480V, 32.0A, 0-500Hz, 15.0kW

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0264 Rev. 00

	MD500L-T15GB(a)	3PH AC 380-480V 41.3A 50/60Hz	3PH AC 0-480V 32.0A 0-500Hz 15.0kW

License condition
All models with input voltage 200-240V~, three phase. When they are used in EU countries, an external 400V~ to 200-240V~ step down transformer should be used.

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®