ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0219 Rev. 00

Holder of Attestation: **Suzhou Inovance Technology Co., Ltd.**
No. 52, Tian E Dang Road, Wuzhong District
215104 Suzhou City, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Electronic frequency converter (AC Drive)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105213045702

Date, 2025-09-16

(Kevin Liu)

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATTESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0219 Rev. 00

Model(s): **CP500T18.5-AT(a), CP500T22-AT(a), CP700-4T18.5-H(a), CP700-4T18.5-H1(a), CP700-4T18.5S-H(a), CP700-4T18.5S-H1(a), CP700-4T22-H(a), CP700-4T22-H1(a), CP700-4T22S-H(a), CP700-4T22S-H1(a), CP701-4T18.5-H(a), CP701-4T18.5-H1(a), CP701-4T18.5S-H(a), CP701-4T18.5S-H1(a), CP701-4T22-H(a), CP701-4T22-H1(a), CP701-4T22S-H(a), CP701-4T22S-H1(a)**

Remark:
Note (a): The model number may include a suffix "XXXXXXXXXX", Where "XXXXXXXXXX" can be blank or combination of any alphanumeric and/or symbols that represents customer identity.

Brand: **INOVANCE**

Parameters:

Rated voltage:	See below table 1-Model list
Rated Current:	See below table 1-Model list
Ambient temperature:	-10 to 50°C
Overvoltage category:	III
Pullotion dgree:	2
Construction:	Built-in
IP code:	IP20
Maximum operation altitude:	2000m
Size:	365mm*284mm*190mm

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0219 Rev. 00

Remark:

- When installing the equipment, all requirements of the mentioned standard must be fulfilled and it should be suitably installed in closed electrical operation area, and fire/mechanical protection enclosure shall be provided.
- The equipment has no overcurrent protective device. For safe operation, a suitable external circuit breaker must be employed before installation.

Table 1- Model list

Series	Model No.	Input	Output1	Output2	Output3
CP500	CP500T18.5-AT(a)	3PH AC 380-440V(-15%-10%) 47.2A 50/60Hz	3PH AC 0-440V 37.0A 0-500Hz 18.5kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	--
	CP500T22-AT(a)	3PH AC 380-440V(-15%-10%) 57.5A 50/60Hz	3PH AC 0-440V 45.0A 0-500Hz 22kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	--
CP700	CP700-4T18.5-H(a)	3PH AC 380-440V 47.2A 50/60Hz	3PH AC 0-440V 37.0A 0-500Hz 18.5kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	3PH AC 380-440V 2.1A 50/60Hz 0.75kW
	CP700-4T18.5-H1(a)	3PH AC 380-440V 47.2A 50/60Hz	3PH AC 0-440V 37.0A 0-500Hz 18.5kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	3PH AC 380-440V 2.1A 50/60Hz 0.75kW
	CP700-4T18.5S-H(a)	3PH AC 380-440V 47.2A 50/60Hz	3PH AC 0-440V 37.0A 0-500Hz 18.5kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	3PH AC 380-440V 2.1A 50/60Hz 0.75kW
	CP700-4T18.5S-H1(a)	3PH AC 380-440V 47.2A 50/60Hz	3PH AC 0-440V 37.0A 0-500Hz 18.5kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	3PH AC 380-440V 2.1A 50/60Hz 0.75kW
	CP700-4T22-H(a)	3PH AC 380-440V 57.5A 50/60Hz	3PH AC 0-440V 45.0A 0-500Hz 22kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	3PH AC 380-440V 2.1A 50/60Hz 0.75kW
	CP700-4T22-H1(a)	3PH AC 380-440V 57.5A 50/60Hz	3PH AC 0-440V 45.0A 0-500Hz 22kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	3PH AC 380-440V 2.1A 50/60Hz 0.75kW

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®

ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. N8A 092835 0219 Rev. 00

CP700	CP700-4T22S-H(a)	3PH AC 380-440V 57.5A 50/60Hz	3PH AC 0-440V 45.0A 0-500Hz 22kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	3PH AC 380-440V 2.1A 50/60Hz 0.75kW
	CP700-4T22S-H1(a)	3PH AC 380-440V 57.5A 50/60Hz	3PH AC 0-440V 45.0A 0-500Hz 22kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	3PH AC 380-440V 2.1A 50/60Hz 0.75kW
CP701	CP701-4T18.5-H(a)	3PH AC 380-440V 47.2A 50/60Hz	3PH AC 0-440V 37.0A 0-500Hz 18.5kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	--
	CP701-4T18.5-H1(a)	3PH AC 380-440V 47.2A 50/60Hz	3PH AC 0-440V 37.0A 0-500Hz 18.5kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	--
	CP701-4T18.5S-H(a)	3PH AC 380-440V 47.2A 50/60Hz	3PH AC 0-440V 37.0A 0-500Hz 18.5kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	--
	CP701-4T18.5S-H1(a)	3PH AC 380-440V 47.2A 50/60Hz	3PH AC 0-440V 37.0A 0-500Hz 18.5kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	--
	CP701-4T22-H(a)	3PH AC 380-440V 57.5A 50/60Hz	3PH AC 0-440V 45.0A 0-500Hz 22kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	--
	CP701-4T22-H1(a)	3PH AC 380-440V 57.5A 50/60Hz	3PH AC 0-440V 45.0A 0-500Hz 22kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	--
	CP701-4T22S-H(a)	3PH AC 380-440V 57.5A 50/60Hz	3PH AC 0-440V 45.0A 0-500Hz 22kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	--
	CP701-4T22S-H1(a)	3PH AC 380-440V 57.5A 50/60Hz	3PH AC 0-440V 45.0A 0-500Hz 22kW	3PH AC 0-440V 2.1A 0-500Hz 0.75kW	--

Tested according to: EN 61800-5-1:2007/A11:2021

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®